

WELL COMPLETION REPORT

3/71

PUTNAM COUNTY DEPARTMENT OF HEALTH

Division of Environmental Health Services

COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

41 28 41 73 32 57

PA27 BREWSTER P1109

OWNER	NAME Stephens, Daniel		ADDRESS 16 Yonkers Place, Patterson, NY 12563	
LOCATION OF WELL	(No. & Street) Overlin Dr., Putnam Lake, Patterson, NY 12563		(Town) (Lot Number)	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC <input type="checkbox"/> BUSINESS ESTABLISHMENT <input type="checkbox"/> FARM <input type="checkbox"/> TEST WELL <input type="checkbox"/> PUBLIC SUPPLY <input type="checkbox"/> INDUSTRIAL <input type="checkbox"/> AIR CONDITIONING <input type="checkbox"/> OTHER (Specify) 690 H			
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY <input type="checkbox"/> COMPRESSED AIR PERCUSSION <input type="checkbox"/> CABLE PERCUSSION <input type="checkbox"/> OTHER (Specify)			
CASING DETAILS	LENGTH (feet) 21 ft	DIAMETER (Inches) 6"	WEIGHT PER FOOT 19 lbs	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED <input type="checkbox"/> DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED <input checked="" type="checkbox"/> PUMPED <input type="checkbox"/> COMPRESSED AIR	HOURS 6	G.P.M. 8	YIELD (G.P.M.) 8 GPM
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet) 30 ft.		DURING YIELD TEST (feet) 155 ft.	
SCREEN DETAILS	MAKE SLOT SIZE DIAMETER (Inches) IF GRAVEL PACKED: Diameter of well including gravel pack (Inches):			LENGTH OPEN TO AQUIFER (feet) GRAVEL SIZE (Inches) FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION
FEET	to FEET	
0	5	Drilling in overburden: clay and boulders
5	21	Hit rock at 5 ft
5	21	Drilling in rock, set casing, grouted
21	155	Drilling in rock-schist

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED
10/17/84DATE OF REPORT
10/23/84

WELL DRILLER (Signature)

Sketch exact location of well with distances, to at least two permanent landmarks.

RECEIVED

10-1-1984

PUTNAM COUNTY
DEPT. OF HEALTH